



ENVIRO-TECH SERVICES

An Analytical Laboratory

(A GOVERNMENT APPROVED LAB)

Plot No. 1/32, S.S. of G.T. Road Industrial Area, Ghaziabad (U.P.) - 201001

email : etslab2012@gmail.com | Website : www.etslab.in | Ph.: 9911516076, 9811736063



TEST REPORT

TEST REPORT NO.: ETS/1005-2/07/2024

ULRNO.TC130092400010052F

DATE OF REPORT: 04.07.2024

WASTE WATER SAMPLE ANALYSIS REPORT

Name And Address of Customer : M/S.ST.JOSEPH'S HOSPITAL BARAMULLA
DISTRICT-BARAMULLA J&K

Date of Sampling : 29.06.2024
Analysis Start Date : 01.07.2024
Analysis End Date : 04.07.2024
Sample ID No : 1005-2
Sampling Done By : ETS STAFF
Sampling Description : BEFORE TREATMENT
Sampling Location : E.T.P. -INLET
Sampling Method : ETS/STP/WATER-02
Sample Quantity : 2.0 Ltr.
Packing Condition : SEALED
Packed In : P.V.C. CANE

S. No.	Test Parameter	Unit	Result	Test Method
1	pH	...	6.92	APHA 4500-H+
2	Total Suspended Solids,(TSS)	mg/L	130.0	APHA 2540-D
3	Oil & Grease, (O & G)	mg/L	5.2	APHA 5520-D
4	Biological Oxygen Demand(BOD _{3d} 27°C)	mg/L	221.0	IS: 3025 (Part-44)
5	Chemical Oxygen Demand,(COD)	mg/L	436.0	APHA 5220-B

CHECKED BY
SHRADDHA GUPTA

For Enviro-Tech Services
AUTHORIZED SIGNATORY
Pushkal Mittal
Lab In-charge

Format No ETS/LAB/TR-10, Issue No. 05, Date 01.04.2019, Amd. No. 04 Date 01.04.2019

Note:-

1. Test reports without ETS LAB HOLOGRAM are not issued by our laboratory.
2. The results indicated only refer to the tested samples and listed applicable parameters.
3. No complaint will be entertained if received after 7 days of issue of test report.
4. Our liability is limited to invoice value only.
5. The sample shall be destroyed after 15 days & Biological / Perishable sample shall be destroyed immediately after issue of test report.
6. This test report shall not be used in any advertising media or as evidence in the court of Law without prior written permission of the laboratory.



TEST REPORT

TEST REPORT NO.: ETS/1005-2/07/2024

DATE OF REPORT: 04.07.2024

WASTE WATER SAMPLE ANALYSIS REPORT

S. No.	Test Parameter	Unit	Result	Test Method
6	Phosphate (P)	mg/L	3.8	APHA 4500:(P)-D
7	Nitrate.(NO ₃)	mg/L	2.5	APHA 4500:(NO ₃)-B

*****End of Test Report*****

CHECKED BY
SHRADDHA GUPTA

For Enviro-Tech Services

AUTHORIZED SIGNATORY

Lab In-charge

Format No ETS/LAB/TR-10, Issue No. 05, Date 01.04.2019, Amd. No. 04 Date 01.04.2019

Note:-

1. Test reports without ETS LAB HOLOGRAM are not issued by our laboratory.
2. The results indicated only refer to the tested samples and listed applicable parameters.
3. No complaint will be entertained if received after 7 days of issue of test report.
4. Our liability is limited to invoice value only.
5. The sample shall be destroyed after 15 days & Biological / Perishable sample shall be destroyed immediately after issue of test report.
6. This test report shall not be used in any advertising media or as evidence in the court of Law without prior written permission of the laboratory.



ENVIRO-TECH SERVICES

An Analytical Laboratory

(A GOVERNMENT APPROVED LAB)

Plot No. 1/32, S.S. of G.T. Road Industrial Area, Ghaziabad (U.P.) - 201001

email : etslab2012@gmail.com | Website : www.etslab.in | Ph.: 9911516076, 9811736063



TC-13009

TEST REPORT

TEST REPORT NO.: ETS/1005-3/07/2024

ULRNO.TC130092400010053F

DATE OF REPORT: 04.07.2024

WASTE WATER SAMPLE ANALYSIS REPORT

Name And Address of Customer : M/S, ST. JOSEPH'S HOSPITAL BARAMULLA
DISTRICT-BARAMULLA J&K

Date of Sampling : 29.06.2024
Analysis Start Date : 01.07.2024
Analysis End Date : 04.07.2024
Sample ID No : 1005-3
Sampling Done By : ETS STAFF
Sampling Description : AFTER TREATMENT
Sampling Location : E.T.P. -OUTLET
Sampling Method : ETS/STP/WATER-02
Sample Quantity : 2.0 Ltr.
Packing Condition : SEALED
Packed In : P.V.C. CANE

S. No.	Test Parameter	Unit	Result	Specification/Limit (As per CPCB)		Test Method
				Inland Surface Water	Public Sewers	
1	pH	...	7.21	5.5 - 9.0	5.5 - 9.0	APHA 4500-H+
2	Total Suspended Solids,(TSS)	mg/L	12.8	100	600	APHA 2540-D
3	Oil & Grease, (O & G)	mg/L	2.6	10	20	APHA 5520-D
4	Biological Oxygen Demand(BOD ₅ 27°C)	mg/L	10.0	30	350	IS: 3025 (Part-44)
5	Chemical Oxygen Demand,(COD)	mg/L	58.0	250	Not Specified	APHA 5220-B



For Enviro-Tech Services
AUTHORIZED SIGNATORY
Pushkar Mittal
Lab In-charge

Format No ETS/LAB/TR-10, Issue No. 05, Date 01.04.2019, Amd. No. 04 Date 01.04.2019

Note:-

1. Test reports without ETS LAB HOLOGRAM are not issued by our laboratory.
2. The results indicated only refer to the tested samples and listed applicable parameters.
3. No complaint will be entertained if received after 7 days of issue of test report.
4. Our liability is limited to invoice value only.
5. The sample shall be destroyed after 15 days & Biological / Perishable sample shall be destroyed immediately after issue of test report.
6. This test report shall not be used in any advertising media or as evidence in the court of Law without prior written permission of the laboratory.



TEST REPORT

TEST REPORT NO.: ETS/1005-3/07/2024

DATE OF REPORT: 04.07.2024

WASTE WATER SAMPLE ANALYSIS REPORT

S. No.	Test Parameter	Unit	Result	Specification/Limit (As per CPCB)		Test Method
				Inland Surface Water	Public Sewers	
6	Phosphate (P)	mg/L	1.1	5	Not Specified	APHA 4500:(P)-D
7	Nitrate, (NO ₃)	mg/L	2.3	10	Not Specified	APHA 4500:(NO ₃)-B

*****End of Test Report*****

CHECKED BY
SHRADDHA GUPTA

For Enviro-Tech Services

AUTHORIZED SIGNATORY
Lab In-charge

Format No ETS/LAB/TR-10, Issue No. 05, Date 01.04.2019, Amd. No. 04 Date 01.04.2019

Note:-

1. Test reports without ETS LAB HOLOGRAM are not issued by our laboratory.
2. The results indicated only refer to the tested samples and listed applicable parameters.
3. No complaint will be entertained if received after 7 days of issue of test report.
4. Our liability is limited to invoice value only.
5. The sample shall be destroyed after 15 days & Biological / Perishable sample shall be destroyed immediately after issue of test report.
6. This test report shall not be used in any advertising media or as evidence in the court of Law without prior written permission of the laboratory.